Cheques, and Postage Stamps will not be accepted towards the cost of forms nor will the forms be sent by V.P.P.

4552

Dated 18th September 1953.

To

The Firms dealing in Bleaching Powder.

Enquiry No. 11862.

Subject :—Bleaching Powder.

Gentlemen,

No. S.P.C. 31589-603. Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the undermentioned schedule in the form printed below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

Withdrawal from the quotation after it is accepted or failure to make all supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Bleaching Powder" with the above enquiry number.

This enquiry will be closed on the 19th October 1953.

SCHEDULE.

	F.O.R.
Bleaching powder any good brand of standerd quality 27 to 30 per cent chlorine in packings of 56 to 84 lbs ...	Bangalore 10 tons.

N.B.—1. The quotations with firm prices will be preferred.
2. Sales-tax, if any, should be quoted separately.
3. The quotations will be opened at 2 P.M. on the next working day after the closing date.

4419

Dated 18th September 1953.

Enquiry No. 11471.

2,000 H.P. Pumpsets for C.R.S. Water Works, Thippagondanahalli.

No. S.P.C. 31702-51. Please note that the closing date of 22nd September 1953 of the above enquiry as notified in this Office Notification No. 19450-90, dated 23rd July 1953, is hereby extended up to 14th December 1953.

No further extension of time will be granted under any circumstances.

4599

Dated 21st September 1953.

To

The Firms dealing in Pump Sets.

Enquiry No. 11864.

Subject.—Pump sets required for Konanur Water Supply.

Gentlemen,

No. S.P.C. 31559-88. Please be good enough to intimate your best prices and the earliest time of delivery for the materials described below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Pumpsets required for Konanur Water Supply" with the above enquiry number.

This enquiry will be closed on the 21st October 1953.

SCHEDULE

	Quantity required.	Price quoted F.O.R.
The pump and motor described below shall be mounted on a common cast iron bed plate and connected by means of a flexible coupling	.....	Hosa-agrahara Railway station, Southern Railways.

Pump.—1. Capacity—100 gallons of reasonably clear water against a total head of 200 ft. from all causes.
2. Type—Horizontal spindle, casing split on the shaft centre line.
3. Impellers—to be of true phospher bronze.

Motor.—1. Power supply available—A C. 3 phase 400—410 volts, 50 cycles.
2. Type—Drip proof totally enclosed, squirrel cage induction motor tropically insulated.
3. H.P. of the motor to be—15 and alternative offers of more or less than 15 H.P. need not be quoted.

Accessories for each set.—

a. Pump.—Foot valve with strainer, pressure-gauge, Vacuum-gauge, priming taudish, delivery sluice valve, non-return valve with bypass arrangement, and a set of spanners to overhaul the pump set.
b. Motor—Auto-transformer type starter-Ammeter and Voltmeter

Spares for each set.

a. Pump—One set of rotating elements complete.
One set of bearings.
b. One set of bearings.

N.B—1. Quotations with firm prices will be preferred.
2. Sales-tax, if any, should be quoted separately.
3. Quotations may be sent in duplicate.
4. No enhancement of prices will be allowed after the acceptance of the tender.
5. Whether your firm has been registered in the Stores Purchase Committee Office as per new rules, may be mentioned.
6. The price quoted should hold to good for a period of three months from the date of opening the tenders, failing which such quotations will not be considered.
7. Quotations will be opened at 2 P.M. on the next working day after the closing date.

4557

Dated 21st September 1953.

To

The Firms dealing in Machine Tools & Hardware Materials.

Enquiry No. 11866.

Subject :—Supply of Air Receiver, etc., for use in Bellara Gold Mines.

Gentlemen,

No. S.P.C. 32043-72. Please be good enough to intimate your best prices and the earliest time of delivery for the materials described below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions.

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for supply of Air Receiver, etc., for use in the Bellara Gold Mines" with the above enquiry number.

This enquiry will be closed on the 19th October 1953.

SCHEDULE.

Item No.	Description of material offered	Quantity	Price quoted F.O.R.	Time of delivery
...	...	...	For delivery free at the Bellara Gold Mines, Chicknaikanahalli Taluk.	
1.	Air Receiver, 3' 6" dia. x 10' high with safety valve and one pressure gauge, drain cock, etc.	One	Tumkur District.	
2.	Circulating Water Pump—English Make 3/4" x 3/4" capacity, 800 gallons per hour at 25 ft. head with ½ H.P. Electric Motor, 50 cycles, 230 volts, 2800 R.P.M.	One	...	
3.	G.I, Pipe of 3" Diameter length ...	1,500 ft,	...	

Note.—1. Quotations with firm prices will be preferred.
2. Sales-tax, should be quoted separately.
3. No enhancement of prices will be allowed after the acceptance of the tender.